

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-1429:122 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Secutron, Div. of Digital Security Controls LTD, 3301 Langstaff Rd, Concord, Ontario Canada L4K 4L2
Contact: Paul Mattern (978) 731-8542 FAX (978) 731-8881

DESIGN: Models MR2506B and MR2506R fire alarm control units. Power limited. Local or releasing service, automatic, manual, waterflow and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120/220 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as fire alarm control unit for use with separately listed compatible initiating and indicating devices. Refer to manufacturer's installation manual for details.

These control units can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition.

XLf: 7165-0026:314

11-19-03



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 22, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager